

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7170-1130:127 Page 1 of 1

**CATEGORY:** Control Unit (High-Rise)

**LISTEE:** \*Honeywell International Inc., 1500 W. Dundee Rd., Arlington Heights IL 60004-1472  
Contact: Bob Hodgson (847) 797-4403 Fax (847) 797-3664

**DESIGN:** Model DELTANET FS90 fire alarm system. Coded or noncoded; local, auxiliary, remote station (protected premises), proprietary and voice communications service; automatic or manual, waterflow, sprinkler supervisory and releasing device service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

CA	Control Module
AA/AB/AC/AE	Initiating Card or Intelligent Loop Card
BF/BG	Alarm Card
VA	Transmitter Module
LA/LB/LC/LD/LH	Communications Card
LJ	RS485 Communications/Display Card
AD	Digital Non-Fire Alarm Card
DA/DC	Accessory Relay Card
LF	Fiber Optic Interface Communications Board
CC	Audio Control Board
CE	Phone Control Board
SB/SH	Audio Select Board
SD	Phone Select Board
SF/SK	HVAC Override Board
AR	Access Control Reader Interface Board
14506817	Printer/Display Assembly

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as a control unit suitable for installation in high-rise structures when used with separately listed compatible initiating and indicating devices. May be interfaced with Model SENTARA 324 control unit (CSFM Listing No. 7165-1130:117) or Model Delta 1000 control unit (CSFM Listing No. 7165-1130:120) for proprietary (protected premises) service. Suitable for use with Dukane Model 12A957 audio adjunct (CSFM Listing No. 6911-0023:008) or DeltaNet Microcentral/Excel Plus or Enterprise Building Integrator proprietary fire alarm receiving system (7165-1130:113).

\*Rev. 06-14-2003TR



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**